## Information requirements for air-to-air conditioners

Model(s):MV6-335WV2GN1-E; Test matching indoor units form, Duct: 6×MI-56T1;

Outdoor side heat exchanger of air conditioner:air

Indoor side heat exchanger of air conditioner:air

## Type:compressor driven

If applicable:driver of compressor:electric motor

Item	Symbol	Value	Unit		Item	Symbol	Value	Unit	
item	Symbol	value	Unit			Symbol	value	Unit	
Rated cooling capacity	P <sub>rated,c</sub>	33.5	kW		Seasonal space cooling energy efficiency	$\eta_{s,c}$	204.7	%	
Declared cooling capacity for part load at given outdoor temperatures $T_j$ and indoor 27/19 $^\circ\!\!\!\!^\circ C$ (dry/wet bulb)					Declared energy efficiency ratio or gas utilisation efficiency/auxilia energy factor for part load at given outdoor temperatures $T_{j}$				
Tj=+35℃	P <sub>dc</sub>	33.5	kW		Tj=+35℃	EERd	2.57		
Tj <b>=+30</b> ℃	P <sub>dc</sub>	23.276	kW		Tj=+30℃	EERd	4.17		
Tj <b>=+25</b> ℃	P <sub>dc</sub>	15.186	kW		Tj=+25℃	EERd	6.65		
T <sub>j</sub> =+20℃	P <sub>dc</sub>	8.719	kW		Tj=+20℃	EERd	8.62		
Degradation co-efficient for air conditioners(*)	C <sub>dc</sub>	0.25	-						
		F	Power consumption in	modes of	her than "active mode"				
Off mode	P <sub>OFF</sub>	0.064	kW		Crankcase heater mode	P <sub>CK</sub>	0.064	kW	
Thermosat-off mode	P <sub>TO</sub>	0	kW		Standby mode	P <sub>SB</sub>	0.064	kW	
			C	ther item	IS				
Capacity control	variable				For air-to-air air conditioner:air flow rate,outdoor measured	_	11000	m³/h	
Sound power level,outdoor	L <sub>WA</sub>	81	dB						
GWP of the refrigerant		2088	kg CO <sub>2 eq</sub> (100years)						
Contact details			· · · · · ·		<u> </u>				
(*)If Cdc is not determined	d by measu	rement then	the default degradation	n coefficie	ent of heat pumps shall be 0.25				

Where information relates to multi-split air conditioners, the test result and performance data may be obtained on the basis of performance of the outdoor unit ,with a combination of indoor unit(s) recommended by the manufacturer or importer

## Information requirements for heat pumps Model(s):MV6-335WV2GN1-E;

Model(s):MV6-335WV2 Test matching indoor ur	,	uct: 6×MI-5	6T1 <sup>.</sup>					
Outdoor side heat exchan								
Indoor side heat exchance	-							
Idication if the heater is e	,		entarv heater:no					
If applicable:driver of con								
	•		ting season,parameters for	the warmer and colder heating seaso	ms are optional			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit	
Rated heating capacity	P <sub>rated,h</sub>	33.5	kW	Seasonal space heating energy efficiency	η <sub>s,h</sub>	133.4	%	
Declared heating capacity for part load at indoor teperature 20 $^{\circ}\text{C}$ and outdoor temperatures $\ensuremath{T_{j}}$				Declared coefficient of performance or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T <sub>j</sub>				
T <sub>j</sub> =-7℃	P <sub>dh</sub>	17.346	kW	Tj=-7℃	COPd	2.44		
T <sub>j</sub> =+2°C	P <sub>dh</sub>	10.544	kW	Tj=+2℃	COPd	3.24		
T <sub>j</sub> =+7°C	P <sub>dh</sub>	7.080	kW	Tj=+7℃	COPd	4.49		
T <sub>j</sub> =+12°C	P <sub>dh</sub>	5.589	kW	T <sub>j</sub> =+12℃	COPd	4.99		
T <sub>biv</sub> =bivalent temperature	P <sub>dh</sub>	17.346	kW	T <sub>biv</sub> =bivalent temperature	COPd	2.44		
T <sub>o∟</sub> =operation temperature	P <sub>dh</sub>	19.730	kW	T <sub>OL</sub> =operation temperature	COPd	2.34		
Bivalent temperature	T <sub>biv</sub>	-7	°C					
Degradation co-efficient for heat pumps(**)	C <sub>dh</sub>	0.25	-					
Power consumption in me	odes other f	han "active r	node"	Supplementary heater				
Off mode	P <sub>OFF</sub>	0.064	kW	Back-up heating capacity(*)	elbu	0	kW	
Thermosat-off mode	P <sub>TO</sub>	0.064	kW	Type of energy input				
Crankcase heater mode	P <sub>CK</sub>	0.124	kW	Standby mode	$P_{SB}$	0.064	kW	
			Other	items				
Capacity control	variable			For air-to-air heat pump:air flow rate,outdoor measured		11000	m³/h	
Sound power level,outdoor	L <sub>WA</sub>	81	dB					
GWP of the refrigerant		2088	kg CO <sub>2 eq</sub> (100years)					
Contact details								
(*)								

(\*)

(\*\*)If  $C_{dh}$  is not determined by measurement then the default degradation coefficient of heat pumps shall be 0.25

Where information relates to multi-split heat pumps, the test result and performance data may be obtained on the basis of performance of the outdoor unit ,with a combination of indoor unit(s) recommended by the manufacturer or importer