TÜV SÜD ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

CE

TÜV SÜD Product Service

Attestation of Conformity

No. N8A 072433 0906 Rev. 01

Holder of Certificate: **GD Midea Heating & Ventilating Equipment Co.,Ltd.**
Penglai Industry Road, Beijiao, Shunde
528311 Foshan, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Product: **Electric fan-coil units (Fan Coil Unit)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance.
It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 6411110122804

Date, 2019-11-04

(Gary Sun)

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

A4 / 07.17

TÜV SÜD ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

Attestation of Conformity

No. N8A 072433 0906 Rev. 01

Model(s):

MKH1-150, MKH2-150, MKH3-150, MKH4-150, MKH5-150, MKH1-250, MKH2-250, MKH3-250, MKH4-250, MKH5-250, MKH1-300, MKH2-300, MKH3-300, MKH4-300, MKH5-300, MKH1-400, MKH2-400, MKH3-400, MKH4-400, MKH5-400, MKH1-450, MKH2-450, MKH3-450, MKH4-450, MKH5-450, MKH1-500, MKH2-500, MKH3-500, MKH4-500, MKH5-500, MKH1-600, MKH2-600, MKH3-600, MKH4-600, MKH5-600, MKH1-800, MKH2-800, MKH3-800, MKH4-800, MKH5-800, MKH1-900, MKH2-900, MKH3-900, MKH4-900, MKH5-900, MKH2-150-R3, MKH2-150-R4, MKH2-250-R3, MKH2-250-R4, MKH2-350-R3, MKH2-350-R4, MKH2-500-R3, MKH2-500-R4, MKH2-700-R3, MKH2-700-R4, MKH2-800-R3, MKH2-800-R4, MKH3-150A, MKH3-250A, MKH3-300A, MKH3-400A, MKH3-450A, MKH3-500A, MKH3-600A, MKH3-800A, MKH3-900A

Brand: **Midea, MDV**

Parameters:

Rated voltage:	220-240V~
Rated frequency:	50Hz
Rated power:	See model list
Protection class:	Class I
Degree of protection:	IPX0
Rated current:	See model list

Model list:

Model	Rated current (A) cooling and heating	Rated power input(W) cooling and heating
MKH1-150	0,12	27
MKH2-150	0,13	29
MKH3-150	0,13	29
MKH4-150	0,12	27
MKH5-150	0,13	29
MKH1-250	0,20	45
MKH2-250	0,20	45
MKH3-250	0,20	45
MKH4-250	0,20	45
MKH5-250	0,20	45

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

TÜV SÜD ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

CE

TÜV SÜD Product Service

Attestation of Conformity

No. N8A 072433 0906 Rev. 01

MKH1-300	0,19	40
MKH2-300	0,20	44
MKH3-300	0,20	44
MKH4-300	0,19	40
MKH5-300	0,20	44
MKH1-400	0,20	46
MKH2-400	0,21	47
MKH3-400	0,21	47
MKH4-400	0,20	46
MKH5-400	0,21	47
MKH1-450	0,20	40
MKH2-450	0,20	40
MKH3-450	0,20	40
MKH4-450	0,20	40
MKH5-450	0,20	40
MKH1-500	0,22	49
MKH2-500	0,23	51
MKH3-500	0,23	51
MKH4-500	0,22	49
MKH5-500	0,23	51
MKH1-600	0,30	77
MKH2-600	0,30	77
MKH3-600	0,30	77
MKH4-600	0,30	77
MKH5-600	0,30	77
MKH1-800	0,50	118
MKH2-800	0,50	118
MKH3-800	0,50	118
MKH4-800	0,50	118
MKH5-800	0,50	118
MKH1-900	0,61	137
MKH2-900	0,64	143
MKH3-900	0,64	143
MKH4-900	0,61	137
MKH5-900	0,64	143
MKH2-150-R3	0,15	35
MKH2-150-R4	0,17	40
MKH2-250-R3	0,20	47
MKH2-250-R4	0,20	47
MKH2-350-R3	0,22	51
MKH2-350-R4	0,22	51
MKH2-500-R3	0,40	91
MKH2-500-R4	0,40	91

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

A4 / 07.17

TÜV SÜD ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

Attestation of Conformity

No. N8A 072433 0906 Rev. 01

MKH2-700-R3	0,53	123
MKH2-700-R4	0,48	110
MKH2-800-R3	0,53	123
MKH2-800-R4	0,51	118
MKH3-150A	0,17	38
MKH3-250A	0,22	50
MKH3-300A	0,24	40
MKH3-400A	0,26	52
MKH3-450A	0,24	42
MKH3-500A	0,27	62
MKH3-600A	0,40	87
MKH3-800A	0,57	129
MKH3-900A	0,67	151

Tested according to:

EN 60335-1:2012/A13:2017
EN 60335-2-40:2003/A13:2012
EN 62233:2008

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

A4 / 07.17