ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD

CE

TÜV SÜD
Product Service

Attestation of Conformity

No. M8A 072433 0518 Rev. 01

Holder of Certificate: **GD Midea Heating & Ventilating Equipment Co.,Ltd.**
Penglai Industry Road, Beijiao, Shunde
528311 Foshan, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Product: **Electric fan-coil units (Fan Coil Unit)**

This Attestation of Conformity is issued on a voluntary basis according to Council Directive 2006/42/EC relating to machinery. It confirms that the listed equipment (not Annex IV equipment) complies with the principal protection requirements of the directive. It refers only to the sample submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: 6411110122804

Date, 2019-11-04 (Gary Sun)

After preparation of the necessary technical documentation as well as the EC declaration of conformity the required CE marking can be affixed on the product. Other relevant directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

A4 / 07.17

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD

CE

TÜV SÜD
Product Service

Attestation of Conformity

No. M8A 072433 0518 Rev. 01

Model(s): **MKH1-150, MKH2-150, MKH3-150, MKH4-150, MKH5-150, MKH1-250, MKH2-250, MKH3-250, MKH4-250, MKH5-250, MKH1-300, MKH2-300, MKH3-300, MKH4-300, MKH5-300, MKH1-400, MKH2-400, MKH3-400, MKH4-400, MKH5-400, MKH1-450, MKH2-450, MKH3-450, MKH4-450, MKH5-450, MKH1-500, MKH2-500, MKH3-500, MKH4-500, MKH5-500, MKH1-600, MKH2-600, MKH3-600, MKH4-600, MKH5-600, MKH1-800, MKH2-800, MKH3-800, MKH4-800, MKH5-800, MKH1-900, MKH2-900, MKH3-900, MKH4-900, MKH5-900, MKH2-150-R3, MKH2-150-R4, MKH2-250-R3, MKH2-250-R4, MKH2-350-R3, MKH2-350-R4, MKH2-500-R3, MKH2-500-R4, MKH2-700-R3, MKH2-700-R4, MKH2-800-R3, MKH2-800-R4, MKH3-150A, MKH3-250A, MKH3-300A, MKH3-400A, MKH3-450A, MKH3-500A, MKH3-600A, MKH3-800A, MKH3-900A**

Trade name: **Midea, MDV**

Parameters:

Rated Voltage:	220-240V~
Rated Frequency:	50Hz
Rated current:	See model list
Rated input:	See model list
Protection Class:	Class I
Degree of Protection:	IPX0

Model list:

Model	Rated current (A) cooling and heating	Rated power input(W) cooling and heating
MKH1-150	0,12	27
MKH2-150	0,13	29
MKH3-150	0,13	29
MKH4-150	0,12	27
MKH5-150	0,13	29
MKH1-250	0,20	45
MKH2-250	0,20	45
MKH3-250	0,20	45
MKH4-250	0,20	45
MKH5-250	0,20	45

After preparation of the necessary technical documentation as well as the EC declaration of conformity the required CE marking can be affixed on the product. Other relevant directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

A4 / 07.17

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD

CE

TÜV SÜD Product Service

Attestation of Conformity

No. M8A 072433 0518 Rev. 01

MKH1-300	0,19	40
MKH2-300	0,20	44
MKH3-300	0,20	44
MKH4-300	0,19	40
MKH5-300	0,20	44
MKH1-400	0,20	46
MKH2-400	0,21	47
MKH3-400	0,21	47
MKH4-400	0,20	46
MKH5-400	0,21	47
MKH1-450	0,20	40
MKH2-450	0,20	40
MKH3-450	0,20	40
MKH4-450	0,20	40
MKH5-450	0,20	40
MKH1-500	0,22	49
MKH2-500	0,23	51
MKH3-500	0,23	51
MKH4-500	0,22	49
MKH5-500	0,23	51
MKH1-600	0,30	77
MKH2-600	0,30	77
MKH3-600	0,30	77
MKH4-600	0,30	77
MKH5-600	0,30	77
MKH1-800	0,50	118
MKH2-800	0,50	118
MKH3-800	0,50	118
MKH4-800	0,50	118
MKH5-800	0,50	118
MKH1-900	0,61	137
MKH2-900	0,64	143
MKH3-900	0,64	143
MKH4-900	0,61	137
MKH5-900	0,64	143
MKH2-150-R3	0,15	35
MKH2-150-R4	0,17	40
MKH2-250-R3	0,20	47
MKH2-250-R4	0,20	47
MKH2-350-R3	0,22	51
MKH2-350-R4	0,22	51
MKH2-500-R3	0,40	91
MKH2-500-R4	0,40	91

After preparation of the necessary technical documentation as well as the EC declaration of conformity the required CE marking can be affixed on the product. Other relevant directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD

CE

TÜV SÜD
Product Service

Attestation of Conformity

No. M8A 072433 0518 Rev. 01

MKH2-700-R3	0,53	123
MKH2-700-R4	0,48	110
MKH2-800-R3	0,53	123
MKH2-800-R4	0,51	118
MKH3-150A	0,17	38
MKH3-250A	0,22	50
MKH3-300A	0,24	40
MKH3-400A	0,26	52
MKH3-450A	0,24	42
MKH3-500A	0,27	62
MKH3-600A	0,40	87
MKH3-800A	0,57	129
MKH3-900A	0,67	151

Tested according to:

EN 60335-1:2012/A13:2017
EN 60335-2-40:2003/A13:2012
EN 62233:2008

After preparation of the necessary technical documentation as well as the EC declaration of conformity the required CE marking can be affixed on the product. Other relevant directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®